

Battery Bank Testing

<b>Facility:</b>	<b>Written By:</b>	<b>Approved By:</b>	<b>Date Created:</b>	<b>Date of Last Revision</b>

<b>Hazards Present:</b>	<b>PPE or Devices Required:</b>	<b>Additional Training Required:</b>
Pinching	Eye protection	
Falls	Steel toed footwear	
Electrical shock		

**Safe Work Procedure:**

1. Turn off the power supply to the batter bank by unplugging the cord, or turning off the breaker.
2. Conduct a walk around to ensure that all remote heads are working
3. Time the operation of the battery to ensure that lights remain on for 30 minutes
4. Turn the power supply back on and record the best results
5. If the "pack" fails, send in a repair notice
6. Perform any required housekeeping

*If an emergency situation occurs while conducting this task, or there is an equipment malfunction, engage the emergency stop and follow the lock out procedure*

**REPORT ANY HAZARDOUS SITUATIONS TO YOUR SUPERVISOR**

<b>Guidance Documents/Standards:</b>  MB Workplace Safety & Health Act & Regulations:	This Safe Work Procedure will be reviewed any time the task, equipment or materials change and at a minimum of every three years
	Reviewed By WSH Committee:  Date: